

INDEX: ☐ YES ☐ NO
 CLASSIFY TO FILE NO. _____
 X-REF TO FILE NO. _____
 FILE RID ☐ RET. TO BRANCH ☐
 DESTROY ☐ SIG. _____

CLASSIFIED MESSAGE

TOTAL COPIES

23

SECRET

GROUP 1
EXCLUDED FROM AUTOMATIC
DOWNGRADING AND
DECLASSIFICATION

REPRODUCTION PROHIBITED

PERSON/UNIT NOTIFIED

1		5	
2		6	
3		7	
4		8	

ACTION

ADVANCE COPY

UNIT

TIME

BY

☐ RID COPY

☐ ISSUED

☐ SLOTTED

☐ TUBED

INFO

FILE, VR, [REDACTED] Kops 4

25X1A

SECRET 270327Z CIT [REDACTED] 0459

27 DEC 67 16876 25X1A



25X1A

B. DIRECTOR 45417

25X1A

1. IN ORDER PROCEED WITH B [REDACTED] A/C AND POWER PLANT PROJECTS
 ASAP, REQUEST COMMENTS ON REF A DESIGNS BE FORWARDED VIA CABLE.

2. MAJOR DESIGN DISCREPANCY NOTED THIS END IS OMISSION OF
 REF B 167 KVA, 208 VOLT DISTRIBUTION TRANSFORMERS TO UPDATE
 EXISTING 100 KVA UNITS. REFER TO SHEET 13 OF POWER PLANT DRAW-
 INGS.

3. THE 167 KVA TRANSFORMERS EXTREMELY DESIRABLE TO PRECLUDE
 TRANSFERRING THE UPS LOAD TO 235 KW GENERATOR IN EVENT UPS IS
 DOWN FOR PROLONGED PERIODS.

4. AS FUNDS ARE AVAILABLE FOR 167 KVA UNITS PER REF B, PLAN
 DIRECT [REDACTED] TO INCLUDE THEM IN FINAL DESIGN.

25X1A

5. FYI: OUR REVIEW BOTH PROJECTS NEARLY COMPLETED. WILL
 MEET WITH [REDACTED] AND A AND E SOON AS COMMENTS RECEIVED FROM YOU.

SECRET


SECRET

OC-E [REDACTED] will send an

Interim reply - pending our completion
 of a review by [REDACTED] R G W.

RECD
C
DCP 12/27/67
EX 12/27/67
C/AC

2



ILLEGAL

25X1A